Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (w	here applicable)	Service	Resider	ntial	Commerci	al Industri	al Combin	ed Agricultural
25 NEW BRITAIN	AVE	Connections	5,87	7	349	47	46	

Towns Served:			
Monitoring	g Requirements		
Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00	600)		
Chlorine Residual (0999)		15 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
Asbestos (1094)		3 routine	(RT) per nine years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/12 - 12/31/20		Complete
Total Coliform (3100)		15 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 rout	ine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
921 FARMINGTON (WWTP) (42001)	10/1/18 - 12/31/18	10/1-10/31	Complete
	1/1/19 - 3/31/19	1/1-1/31	Complete
	4/1/19 - 6/30/19	4/1-4/30	
	7/1/19 - 9/30/19	7/1-7/31	
1820 NEW BRITAIN AVE (43001A)	10/1/18 - 12/31/18	10/1-10/31	Complete
	1/1/19 - 3/31/19	1/1-1/31	Complete
	4/1/19 - 6/30/19	4/1-4/30	
	7/1/19 - 9/30/19	7/1-7/31	
258 MAIN ST FARMG (4752A)	10/1/18 - 12/31/18	10/1-10/31	Complete
	1/1/19 - 3/31/19	1/1-1/31	Complete
	4/1/19 - 6/30/19	4/1-4/30	
	7/1/19 - 9/30/19	7/1-7/31	
RT10 PS WATERVILLE (4753)	10/1/18 - 12/31/18	10/1-10/31	Complete
	1/1/19 - 3/31/19	1/1-1/31	Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Page 1

Schedule Generation Date: 4/11/2019

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (w	here applicable)	Service	Resider	ntial	Commerci	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46	

Towns Served:			
Monitori	ing Requirements		
Water System Facility: DISTRIBUTION SYSTEM (WSF ID:	00600)		
Disinfectant Byproducts - TTHM & HAA5 (DBP)			ine (RT) per quarte
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	4/1/19 - 6/30/19	4/1-4/30	
	7/1/19 - 9/30/19	7/1-7/31	
Lead And Copper (PBCU)		30 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/22	6/1-9/30	
Physical Parameters (PPS)		15 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Water System Facility: ENTRY POINT - WELLCTSS (WSF II	D: 00703)		
Net Gross Alpha (4000)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL CTS (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Uranium (4006)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL CTS (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL CTS (3)	1/1/17 - 12/31/19		·
	1/1/20 - 12/31/22		
Gross Beta Particle Activity (4100)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL CTS (3)	1/1/17 - 12/31/19		-
· ·	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (v	where applicable)	Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46	

Towns Served:

Towns Served:	- Deguines as to		
	g Requirements		
Vater System Facility: ENTRY POINT - WELLCTSS (WSF ID:	00703)		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine	(RT) per three year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL CTS (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
ritium (4102)		1 routine	(RT) per three year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Statu
EP - WELL CTS (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
trontium-90 (4174)		1 routine	(RT) per three year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Statu
EP - WELL CTS (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
norganic Chemicals (IOCS)		1 routine	(RT) per three year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Statu
EP - WELL CTS (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
litrate And Nitrite (NOX)		1 r	outine (RT) per yea
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Statu
EP - WELL CTS (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		2 routine	(RT) per three year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Statu
EP - WELL CTS (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		2 routine	(RT) per three year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Statu
EP - WELL CTS (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 rout	ine (RT) per quarte
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Statu
EP - WELL CTS (3)	10/1/18 - 12/31/18		Out of Service
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
/ater System Facility: ENTRY POINT - WELLP (WSF ID: 007			
Net Gross Alpha (4000)	•	1 routine	(RT) per three year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Statu
EP - WELL P (3)	1/1/17 - 12/31/19	20	Complete
	1/1/20 - 12/31/22		Somplete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (v	where applicable)	Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46	

Towns Served:			<u> </u>
Monitoring Re	equirements		
Water System Facility: ENTRY POINT - WELLP (WSF ID: 00705)			
Uranium (4006)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL P (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Combined Radium-226/228 (4010)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL P (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Inorganic Chemicals (IOCS)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL P (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 r	outine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL P (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		2 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL P (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		2 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL P (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 r	outine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL P (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Water System Facility: ENTRY POINT - WELLS 1, 2, 3, 4 & 5 (WS	F ID: 00707)		
Dieldrin (2070)		1 rout	ine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELLS 1, 2, 3, 4 & 5 (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	4/1/19 - 6/30/19 7/1/19 - 9/30/19		
Net Gross Alpha (4000)		1 routine	(RT) per three years
Net Gross Alpha (4000) Sampling Point (Sampling Point ID)		1 routine Collection Period	(RT) per three years Compliance Status

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Page 4

Schedule Generation Date: 4/11/2019

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Clas	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (where applicable)		Service	Resider	ntial	Commerci	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46	

Towns Served:					
Monitoring	Requirements				
Water System Facility: ENTRY POINT - WELLS 1, 2, 3, 4 & 5	WSF ID: 00707)				
Net Gross Alpha (4000)		1 routine	(RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
	1/1/20 - 12/31/22				
Uranium (4006)		1 routine	(RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
Combined Radium-226/228 (4010)		1 routine	(RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/17 - 12/31/19		Complete		
	1/1/20 - 12/31/22				
Inorganic Chemicals (IOCS)		1 routine	(RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/16 - 12/31/18		Complete		
	1/1/19 - 12/31/21				
	1/1/22 - 12/31/24				
Nitrate And Nitrite (NOX)		1 r	outine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/18 - 12/31/18		Complete		
	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine	(RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/17 - 12/31/19				
	1/1/20 - 12/31/22				
Organic Chemicals (VOCS)		1 r	outine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
EP - WELLS 1, 2, 3, 4 & 5 (3)	1/1/18 - 12/31/18		Complete		
	1/1/19 - 12/31/19		Complete		
	1/1/20 - 12/31/20				
Water System Facility: ENTRY POINT - FIP WELL #3 (WSF ID	: 00708)				
Nitrate (1040)		1 rout	ine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
EP - FIP WELL #3 (3)	10/1/18 - 12/31/18		Out of Service		
	1/1/19 - 3/31/19				
	4/1/19 - 6/30/19				
	7/1/19 - 9/30/19				
Nitrite (1041)		1 r	outine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status		
EP - FIP WELL #3 (3)	1/1/18 - 12/31/18		Out of Service		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section									
Water Quality Monitoring and Compliance Schedule									
PWS Name	Classification	Population	Owner Type	Primary So					

PWS ID	PWS Name			Class	sification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (v	here applicable)	Service	Residen	itial (Commercia	l Industria	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,877	7	349	47	46	

Towns Served:			
Monitorin	g Requirements		
Water System Facility: ENTRY POINT - FIP WELL #3 (WSF IE	D: 00708)		
Nitrite (1041)		1 r	outine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Inorganic Chemicals (IOCS)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - FIP WELL #3 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - FIP WELL #3 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 rout	ine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - FIP WELL #3 (3)	10/1/18 - 12/31/18		Out of Service
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Water System Facility: ENTRY POINT - FIP WELL #4 (WSF IE	D: 00709)		
Inorganic Chemicals (IOCS)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - FIP WELL #4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 r	outine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - FIP WELL #4 (3)	1/1/18 - 12/31/18		Out of Service
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - FIP WELL #4 (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 rout	ine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - FIP WELL #4 (3)	10/1/18 - 12/31/18		Out of Service
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Water System Facility: PONDWOOD WELL (WSF ID: 1028)			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Clas	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (where applicable)		Service	Resider	ntial	Commerci	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46	

Towns Served:

Monitoring Requirements						
Water System Facility: PONDWOOD WELL (WSF ID: 1028)						
E. Coli (3014)		1 rou	tine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status			
PONDWOOD WELL (2)	11/1/18 - 11/30/18		Complete			
	12/1/18 - 12/31/18		Complete			
	1/1/19 - 1/31/19		Complete			
	2/1/19 - 2/28/19		Complete			
	3/1/19 - 3/31/19					
	4/1/19 - 4/30/19					
	5/1/19 - 5/31/19	_				
	6/1/19 - 6/30/19					
	7/1/19 - 7/31/19					
	8/1/19 - 8/31/19					
	9/1/19 - 9/30/19					
	10/1/19 - 10/31/19					
Water System Facility: FIP WELL #3 (WSF ID: 10829)						
E. Coli (3014)		1 rou	tine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status			
FIP WELL #3 (2)	11/1/18 - 11/30/18		Out of Service			
	12/1/18 - 12/31/18		Out of Service			
	1/1/19 - 1/31/19		Out of Service			
	2/1/19 - 2/28/19		Out of Service			
	3/1/19 - 3/31/19		Out of Service			
	4/1/19 - 4/30/19					
	5/1/19 - 5/31/19					
	6/1/19 - 6/30/19					

Water System Facility:	FIP WELL #4	(WSF ID: 10830)
------------------------	-------------	-----------------

Coli (3014)		1 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
FIP WELL #4 (2)	11/1/18 - 11/30/18		Out of Service
	12/1/18 - 12/31/18		Out of Service
	1/1/19 - 1/31/19		Out of Service
	2/1/19 - 2/28/19		Out of Service
	3/1/19 - 3/31/19		Out of Service
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		

7/1/19 - 7/31/19 8/1/19 - 8/31/19 9/1/19 - 9/30/19 10/1/19 - 10/31/19

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Water Quality Monitoring and Compliance Schedule									
PWS ID PWS Name Classification Population Owner Type Primary Source									
CT0520011 CTWC - UNIONVILLE SYSTEM				С	14,693	Р		SWP	
Local Address (where applicable)		Service	Residen	itial Commerc		al Industri	al Combine	ed	Agricultural
, , , , ,		Connections	5,87	7	349	47	46		

Connecticut Department of Public Health Drinking Water Section

Towns Served:			-
Monitorir	ng Requirements		
Water System Facility: FIP WELL #4 (WSF ID: 10830)			
E. Coli (3014)		1 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Water System Facility: C HOUSE WELL 2 (WSF ID: 1298)			
Dieldrin (2070)		1 rout	ine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
C HOUSE WELL 2 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
C HOUSE WELL 2 (2)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
C HOUSE WELL 2 (2)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Water System Facility: C HOUSE WELL 1 (WSF ID: 1299)			
Dieldrin (2070)		1 rout	ine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
C HOUSE WELL 1 (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
C HOUSE WELL 1 (2)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
C HOUSE WELL 1 (2)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Water System Facility: CT SAND & STONE WELL #1 (WSF I	D: 1452)		
E. Coli (3014)		1 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

11/1/18 - 11/30/18

Out of Service

Page 8

Schedule Generation Date: 4/11/2019

CT. SAND AND STONE W (2)

	Connecticut Department of Public Health Drinking Water Section									
	Water Quality Monitoring and Compliance Schedule									
PWS ID	WS ID PWS Name Classification Population Owner Type Primary So						mary Source			
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р		SWP	
Local Address (\	Local Address (where applicable) Service Resi				Commercia	al Industri	al Combine	ed	Agricultural	
25 NEW BRITAII	Connections	5,877	7	349	47	46				

Towns Served:

	Monitorin	g Require	ements		
Water System Facility:	CT SAND & STONE WELL #1 (WSF I	D: 1452)			
E. Coli (3014)				1 rou	utine (RT) per month
Sampling Point (Samp	pling Point ID)	Мо	nitoring Period	Collection Period	Compliance Status
		12/	1/18 - 12/31/18		Out of Service
		1/	1/19 - 1/31/19		Out of Service
		2/	1/19 - 2/28/19		Out of Service
		3/	1/19 - 3/31/19		Out of Service
		4/	1/19 - 4/30/19		
		5/	1/19 - 5/31/19		
		6/	1/19 - 6/30/19		
		7/	1/19 - 7/31/19		
		8/	1/19 - 8/31/19		
		9/	1/19 - 9/30/19		
		10/	1/19 - 10/31/19		
Mor	nthly Water System Facility	(WSF) Lev	el Monitori	ng Requiremer	nts
Water System Facility: I	ENTRY POINT - WELLCTSS (WSFID:	00703)			
Analyte	Monitoring Requirement (Summary T	уре)	Operating Limit	:	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitori	ing (CHLR)	Minimum: 0.2 I	MG/L	Daily
Start Date: 5/1/2003		Compliance	e History:	Operating Limit	Monitoring
		Monitoring	Period	Compliance Status:	Compliance Status:
		11/1/2018	11/30/2018		N
		12/1/2018	12/31/2018		N
		1/1/2019 -	1/31/2019		N
		2/1/2019 -	2/28/2019		N
		3/1/2019 - 3	3/31/2019		
		4/1/2019 -	4/30/2019		
Analyte	Monitoring Requirement (Summary T	уре)	Operating Limit	:	Samples Req/Month
рН	Entry Point pH Monitoring (PHRD)		Minimum: 6.4 l	PH	Daily
Start Date: 5/1/2003		Compliance	e History:	Operating Limit	Monitoring
		Monitoring	Period		Compliance Status:
		11/1/2018	- 11/30/2018		N
		12/1/2018	12/31/2018		N
		1/1/2019 -	1/31/2019		N
		2/1/2019 - :	2/28/2019		N
		3/1/2019 - :	3/31/2019		

4/1/2019 - 4/30/2019

	Conne	ecticut Department of			,			ion	
		Water Quality Monito	oring and	d Compl	liance	Schedul	le		
PWS ID	PWS Nam	e		Cla	ssification	Population	Owner	Type Pr	imary Source
CT0520011	CTWC - U	NIONVILLE SYSTEM			С	14,693	P		SWP
Local Address (where appl	,	Service	Residential	Commerc	ial Industri	al Co	mbined	Agricultural
25 NEW BRITAI	N AVE		Connections	5,877	349	47		46	
Towns Served:									
Water System	Facility:	ENTRY POINT - WELLP (WSFID: 0	00705)						
Analyte		Monitoring Requirement (Summa	ry Type)	Operati	ng Limit		Sar	nples Re	q/Month
Chlorine		Entry Point Chlorine Residual Moni	toring (CHLR) Minimu	m: 0.2 M	i/L		Dai	ly
Start Date:	5/1/2003		Complia	nce History:	0	perating Lim	it l	Monitor	ing
			Monitor	ing Period	C	ompliance St	atus:	Complia	nce Status:
			11/1/20	18 - 11/30/20	018				N
			12/1/20	18 - 12/31/20	018				N
			1/1/2019	9 - 1/31/2019	9				N
				9 - 2/28/2019					N
				9 - 3/31/2019					
				9 - 4/30/2019	9				
Water System	Facility:	ENTRY POINT - WELLS 1, 2, 3, 4 8	& 5 (WSFID:	00707)					
Analyte		Monitoring Requirement (Summa	ry Type)	Operati	ng Limit		Sar	nples Re	q/Month
Chlorine		Entry Point RDC (EPRD)		Minimu	m: 0.50 M	G/L		Dai	ly
Start Date:	7/1/2018		Complia	nce History:	0	perating Lim	it	Monitor	ing
				ing Period		ompliance St	atus:	Complia	nce Status:
			11/1/20	18 - 11/30/20	018	Υ			Υ
				18 - 12/31/20		Y			Υ
				9 - 1/31/2019		Υ			Υ
				9 - 2/28/2019		Υ			Υ
				9 - 3/31/2019		Υ			Υ
				9 - 4/30/2019					
Analyte		Monitoring Requirement (Summa		-	ng Limit		Sar	-	q/Month
рН		Entry Point pH Monitoring (PHRD)			m: 6.4 PH			Dai	ly
Start Date:	5/1/2018		-	nce History:	U	perating Lim		Monitor	_
				ing Period		ompliance St	atus:	Complia	nce Status:
				18 - 11/30/20					N
				18 - 12/31/20					N
				9 - 1/31/2019					N
				9 - 2/28/2019					N
				9 - 3/31/2019					
Motor Cost	Facility	ENITRY DOINT FIRMS (142 /142)		9 - 4/30/2019	9				
•	racility:	ENTRY POINT - FIP WELL #3 (WS	•						/0.0 ::
Analyte		Monitoring Requirement (Summa		-	ng Limit	. //	Sar	-	q/Month
Chlorine	4 /4 /2006	Entry Point Chlorine Residual Moni	• •	•	m: 0.2 MG			Dai	•
Start Date:	1/1/2006		-	nce History:	U	perating Lim		Monitori	_
				ing Period		ompliance St	atus:	compila	nce Status:
				18 - 11/30/20 18 - 12/21/20					N
				18 - 12/31/20					N
				9 - 1/31/2019					N
				9 - 2/28/2019					N
			3/1/201	9 - 3/31/2019	7				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

	Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule										
	Water Quality Mo	onitoring and	a Con	npi	liance S	chedul	.e				
PWS ID PWS Name Classification Population Owner Type Primary Source							Primary Source				
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP			
Local Address	(where applicable)	Service	Residen	itial	Commercia	al Industri	al Combine	ed Agricultural			
25 NEW BRITA	Connections	5,87	7	349	47	46					
Towns Served		•									

Towns Served:						
Water System	Facility:	ENTRY POINT - FIP WELL #3 (WSFID:	: 00708)			
Analyte		Monitoring Requirement (Summary Ty	/pe)	Operating Limit		Samples Req/Month
Chlorine		Entry Point Chlorine Residual Monitorin	ng (CHLR)	Minimum: 0.2	MG/L	Daily
Start Date:	1/1/2006		Compliance	History:	Operating Limit	Monitoring
			Monitoring	Period	Compliance Status	: Compliance Status:
			4/1/2019 - 4	/30/2019		
Water System	Facility:	ENTRY POINT - FIP WELL #4 (WSFID:	: 00709)			
Analyte		Monitoring Requirement (Summary Ty	/pe)	Operating Limit	:	Samples Req/Month
Chlorine		Entry Point Chlorine Residual Monitorin	ng (CHLR)	Minimum: 0.2	MG/L	Daily
Start Date:	1/1/2006		Compliance	History:	Operating Limit	Monitoring
			Monitoring	Period	Compliance Status	: Compliance Status:
			11/1/2018 -	11/30/2018		N
			12/1/2018 -	12/31/2018		N
			1/1/2019 - 1	/31/2019		N

Other Comp	oliance Schedules	
Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2016	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019	3/14/2019
SUBMIT CCR CERTIFICATION FORM	8/9/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	

2/1/2019 - 2/28/2019

3/1/2019 - 3/31/2019 4/1/2019 - 4/30/2019 Ν

	vval	er system raciii	ity and Sampling P	omt ir	iventoi	•		
Water System Facility IL	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPF
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	Α	Υ			
		42001	921 FARMINGTON (WWTP	Α				Υ
		43001	1814 NEW BRITAIN AVE	1				Υ
		43001A	1820 NEW BRITAIN AVE	Α				Υ
		47401	11 DEEPWOOD RD	Α		3		
		47402	9 CUTLER LANE	Α		1		
		47403	3 LARCHWOOD WEST	Α		N		
		47404	33 FIELD STONE	Α		1		
		47405	9 STONEGATE	Α		N		
		47406	5 NEWBURY COURT	Α		N		
		47407	4 VIRGINIA LANE	Α		N		
		47409	5 BURKE CROSSING	Α		N		
		47410	11 VIRGINIA LANE	Α		N		
		47411	62 OAKRIDGE	Α		N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Clas	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (where applicable)	Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAI	N AVE	Connections	5,87	7	349	47	46	

Wat	er System Facili	ity and Sampling P	oint In	ventor	v			
Water				Total	Lead and			
System Water System Facility	Sampling Point	Sampling Point		Coliform	Copper			Stage
acility ID	ID	Description	Status	Rule		Asbestos	WQP .	2 DBP
	47412	11 TALLWOOD	Α		1			
	47413	11 LARCHWOOD WEST	Α		N			
	47414	4 ESSEX COURT	Α		1			
	47415	36 CANTERBURY LANE	Α		1			
	47416	4 COBBLESTONE	Α		N			
	47417	33 CANTERBURY LANE	Α		1			
	47418	33 OAKRIDGE	Α		N			
	47419	7 BLENHEIM TERRACE	Α		N			
	47420	10 ESSEX COURT	Α		1			
	47421	1 ESSEX COURT	Α		1			
	47422	15 COPE FARMS RD	Α		1			
	47423	7 VIRGINIA LANE	Α		N			
	47424	12 COPE FARMS RD	Α		1			
	47425	9 SHIPS OAK	Α		1			
	47426	7 HARTFIELD LANE	Α		1			
	47427	62 COPE FARMS RD	Α		1			
	47428	5 COPE FARMS RD	Α		1			
	47429	6 SHIPS OAK LANE	Α		1			
	47430	12 MALS WAY	Α		N			
	47460	36 SPRING LANE	Α		3			
	47461	26 BASSWOOD RD	Α	Υ	1			
	47462	68 BASSWOOD RD	Α	Υ	1			
	47463	70 BASSWOOD RD	Α	Υ	1			
	47464	14 BLUEBERRY LN	Α	Υ	1			
	47465	243 BRICKYARD RD	Α	Υ	1			
	47466	248 BRICKYARD RD	Α	Υ	1			
	47467	2 COPE FARMS RD	Α	Υ	1			
	47468	4 COPE FARMS RD	Α	Y	1			
	47469	6 COPE FARMS RD	Α	Y	1			
	47470	7 COPE FARMS RD	P	Y	1			
	47471	8 COPE FARMS RD	P	Y	1			
	47472	10 COPE FARMS RD	Р	Y	1			
	47473	11 COPE FARMS RD	Р	Y	1			
	47474	11 COPE FARMS RD	' P	Y	1			
	47475	14 COPE FARMS RD	P	Y	1			
	47476	16 COPE FARMS RD	P	Y	1			
	47477	17 COPE FARMS RD	P	Y	1			
	47477 47478	18 COPE FARMS RD	P	Υ	1			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Clas	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (where applicable)	Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAI	N AVE	Connections	5,87	7	349	47	46	

Towns Served:							
Wat	er System Facili	ity and Sampling	Point In	ventor	У		
Water	•	, ,		Total	Lead and		
System Water System Facility	Sampling Point	Sampling Point		Coliform	Copper		Stage
Facility ID	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2 DBPF
	47479	19 COPE FARMS RD	Р	Υ	1		
	47480	20 COPE FARMS RD	Р	Υ	1		
	47481	22 COPE FARMS RD	Р	Υ	1		
	47482	23 COPE FARMS RD	Р	Υ	1		
	47483	24 COPE FARMS RD	Р	Υ	1		
	47484	25 COPE FARMS RD	Р	Υ	1		
	47485	26 COPE FARMS RD	Р	Υ	1		
	47486	27 COPE FARMS RD	Р	Υ	1		
	47487	28 COPE FARMS RD	Р	Υ	1		
	47488	29 COPE FARMS RD	Р	Υ	1		
	47489	30 COPE FARMS RD	Р	Υ	1		
	47490	31 COPE FARMS RD	Р	Υ	1		
	47491	32 COPE FARMS RD	Р	Υ	1		
	47492	33 COPE FARMS RD	Р	Υ	1		
	47493	34 COPE FARMS RD	Р	Υ	1		
	47494	35 COPE FARMS RD	Р	Υ	1		
	47495	36 COPE FARMS RD	Р	Υ	1		
	47496	37 COPE FARMS RD	Р	Υ	1		
	47497	38 COPE FARMS RD	Р	Υ	1		
	47498	39 COPE FARMS RD	Р	Υ	1		
	47499	40 COPE FARMS RD	Р	Υ	1		
	47500	41 COPE FARMS RD	Р	Υ	1		
	47501	43 COPE FARMS RD	Р	Υ	1		
	47502	44 COPE FARMS RD	Р	Υ	1		
	47503	45 COPE FARMS RD	Р	Υ	1		
	47504	46 COPE FARMS RD	Р	Υ	1		
	47505	47 COPE FARMS RD	Р	Υ	1		
	47506	48 COPE FARMS RD	Р	Υ	1		
	47507	49 COPE FARMS RD	Р	Υ	1		
	47508	51 COPE FARMS RD	Р	Υ	1		
	47509	57 COPE FARMS RD	Р	Υ	1		
	4751	12 MILL ST, UNIONVIL	Α	Υ		Υ	
	47510	59 COPE FARMS RD	Р	Υ	1		
	47511	60 COPE FARMS RD	Р	Υ	1		
	47512	61 COPE FARMS RD	Р	Υ	1		
	47513	63 COPE FARMS RD	Р	Υ	1		
	47514	64 COPE FARMS RD	Р	Υ	1		
	47515	65 COPE FARMS RD	Р	Υ	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Clas	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (v	where applicable)	Service	Resider	itial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46	

Wat	er System Facili	ity and Sampling	Point In	ventor	У		
Water	•	, ,		Total	Lead and		
System Water System Facility	Sampling Point	Sampling Point		Coliform	Copper		Stage
acility ID	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2 DBP
	47516	66 COPE FARMS RD	Р	Υ	1		
	47517	67 COPE FARMS RD	Р	Υ	1		
	47518	68 COPE FARMS RD	Р	Υ	1		
	47519	69 COPE FARMS RD	Р	Υ	1		
	4751X	20 SOUTH MAIN ST	1	Υ		Υ	
	47520	70 COPE FARMS RD	Р	Υ	1		
	47521	75 COPE FARMS RD	Р	Υ	1		
	47522	77 COPE FARMS RD	Р	Υ	1		
	47523	78 COPE FARMS RD	Р	Υ	1		
	47524	79 COPE FARMS RD	Р	Υ	1		
	47525	81 COPE FARMS RD	Р	Υ	1		
	47526	14 CROSSWOOD RD	Р	Υ	1		
	47527	16 CROSSWOOD RD	Р	Υ	1		
	47528	26 CROSSWOOD RD	Р	Υ	1		
	47529	27 CROSSWOOD RD	Р	Υ	1		
	4752A	258 MAIN ST FARMG	Α	Υ		Υ	Υ
	4752B	254 MAIN ST FARMG	Α	Υ			Υ
	4753	RT10 PS WATERVILLE	Α	Υ			Υ
	47530	28 CROSSWOOD RD	Р	Υ	1		
	47531	30 CROSSWOOD RD	Р	Υ	1		
	47532	32 CROSSWOOD RD	Р	Υ	1		
	47533	35 CROSSWOOD RD	Р	Υ	1		
	47534	36 CROSSWOOD RD	Р	Υ	1		
	47535	37 CROSSWOOD RD	Р	Υ	1		
	47536	38 CROSSWOOD RD	Р	Υ	1		
	47537	39 CROSSWOOD RD	Р	Υ	1		
	47538	40 CROSSWOOD RD	Р	Υ	1		
	47539	42 CROSSWOOD RD	P	Y	1		
	4753A	3 PHEASANT HILL	A	Y	_		
	4754	WELLS DRIVE	Α	Y			
	47540	44 CROSSWOOD RD	P	Y	1		
	47541	47 CROSSWOOD RD	Р	Υ	1		
	47542	48 CROSSWOOD RD	Р	Υ	1		
	47543	3 CUTLER LN	r P	Y	1		
	47544 47544	4 CUTLER LN	P P	Υ	1		
	47545	5 CUTLER LN	P P	Υ	1		
			P P	Υ			
	47546 47547	6 CUTLER LN 7 CUTLER LN	P P	Υ Υ	1 1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Classific	cation P	opulation	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM			С		14,693	Р	SWP
Local Address (w	here applicable)	Service	Residen	tial Con	nmercial	Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,877	7	349	47	46	

Towns Served:							
Wate	er System Facili	ity and Sampling I	Point In	ventor	У		
Water	•	, ,		Total	Lead and		
System Water System Facility		Sampling Point		Coliform	Copper		Stage
Facility ID	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2 DBPR
	47548	8 CUTLER LN	Р	Υ	1		
	47549	10 CUTLER LN	Р	Υ	1		
	4755	HUCKLEBERRY HILL PS	Α	Υ			
	47550	11 CUTLER LN	Р	Υ	1		
	47551	12 CUTLER LN	Р	Υ	1		
	47552	2 DEEPWOOD RD	Р	Υ	1		
	47553	3 DEEPWOOD RD	Р	Υ	1		
	47554	4 DEEPWOOD RD	Р	Υ	1		
	47555	2 ESSEX CT	Р	Υ	1		
	47556	3 ESSEX CT	Р	Υ	1		
	47557	5 ESSEX CT	Р	Υ	1		
	47558	8 ESSEX CT	Р	Υ	1		
	47559	11 ESSEX CT	Р	Υ	1		
	4756	KNOLLWOOD PS	Α	Υ		Υ	
	47560	12 ESSEX CT	Р	Υ	1		
	47561	14 ESSEX CT	Р	Υ	1		
	47562	17 FIELDSTONE RUN	Р	Υ	1		
	47563	23 FIELDSTONE RUN	Р	Υ	1		
	47564	25 FIELDSTONE RUN	Р	Υ	1		
	47565	35 FIELDSTONE RUN	Р	Υ	1		
	47566	39 FIELDSTONE RUN	Р	Υ	1		
	47567	47 FIELDSTONE RUN	Р	Υ	1		
	47568	73 FIELDSTONE RUN	Р	Υ	1		
	47569	95 FIELDSTONE RUN	Р	Υ	1		
	4757	PONDWOOD PS	1	Υ			
	47570	187 GARDEN ST	Р	Υ	1		
	47571	2 GLENEAGLES DR	Р	Υ	1		
	47572	3 GLENEAGLES DR	Р	Υ	1		
	47573	3 GLENMORE DR	Р	Υ	1		
	47574	4 GLENMORE DR	Р	Υ	1		
	47575	5 GLENMORE DR	Р	Υ	1		
	47576	6 GLENMORE DR	Р	Υ	1		
	47577	7 GLENMORE DR	Р	Υ	1		
	47578	9 GLENMORE DR	Р	Υ	1		
	47579	11 GLENMORE DR	Р	Υ	1		
	4758	14 LITCHFIELD RD	ı			Υ	
	47580	12 GLENMORE DR	Р	Υ	1		
	47581	14 GLENMORE DR	Р	Υ	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Clas	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (v	where applicable)	Service	Resider	itial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46	

Wat	er System Facili	ity and Sampling P	oint In	ventor	v		
Water		ity and sampling i		Total	Lead and		
System Water System Facility	Sampling Point	Sampling Point		Coliform	Copper		Stage
Facility ID	ID	Description	Status	Rule		Asbestos	_
	47582	14 GLENMORE DR	Р	Υ	1		
	47583	17 GLENMORE DR	Р	Υ	1		
	47584	98 HAROLD RD	Р	Υ	1		
	47585	23 HAROLD RD	Р	Υ	1		
	47586	45 HAROLD RD	Р	Υ	1		
	47587	58 HAROLD RD	Р	Υ	1		
	47588	59 HAROLD RD	Р	Υ	1		
	47589	60 HAROLD RD	Р	Υ	1		
	4759	FOREST PARK BLDG 4	Α				
	47590	61 HAROLD RD	Р	Υ	1		
	47591	63 HAROLD RD	Р	Υ	1		
	47592	64 HAROLD RD	Р	Υ	1		
	47593	65 HAROLD RD	Р	Υ	1		
	47594	67 HAROLD RD	Р	Υ	1		
	47595	71 HAROLD RD	Р	Υ	1		
	47596	74 HAROLD RD	Р	Υ	1		
	47597	75 HAROLD RD	Р	Υ	1		
	47598	77 HAROLD RD	Р	Υ	1		
	47599	78 HAROLD RD	Р	Υ	1		
	4760	362 SCOTT SWAMP RD	Α	Υ			
	47600	79 HAROLD RD	Р	Υ	1		
	47601	81 HAROLD RD	Р	Υ	1		
	47602	82 HAROLD RD	Р	Υ	1		
	47603	83 HAROLD RD	Р	Υ	1		
	47604	85 HAROLD RD	Р	Υ	1		
	47605	87 HAROLD RD	Р	Υ	1		
	47606	93 HAROLD RD	Р	Υ	1		
	47607	94 HAROLD RD	P	Υ	1		
	47608	99 HAROLD RD	Р	Υ	1		
	47609	100 HAROLD RD	Р	Υ	1		
	4761	16 SPRING LANE	A	Y	N		
	47610	102 HAROLD RD	P	Y	1		
	47611	103 HAROLD RD	P	Y	1		
	47612	104 HAROLD RD	Р	Y	1		
	47613	105 HAROLD RD	, P	Y	1		
	47614	106 HAROLD RD	P	Y	1		
	47615	110 HAROLD RD	r P	Y	1		
	47616	2 HARTFIELD LN	P	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (v	vhere applicable)	Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	N AVE	Connections	5,87	7	349	47	46	

Wa	ter System Facili	ity and Sampling F	oint In	ventor	v			
Water	ter system ruem	ity and sampling i	Jiiic iii	Total	Lead and			
System Water System Facility	Sampling Point	Sampling Point		Coliform	Copper			Stage
Facility ID	ID	Description	Status	Rule		Asbestos	WQP .	_
	47617	3 HARTFIELD LN	Р	Υ	1			
	47618	6 HARTFIELD LN	Р	Υ	1			
	47619	6 HARTFIELD LN	Р	Υ	1			
	4762	25 NEW BRITAIN AVE	Α	Υ				
	47620	7 HARTFIELD LN	Р	Υ	1			
	47621	8 HARTFIELD LN	Р	Υ	1			
	47622	9 HARTFIELD LN	Р	Υ	1			
	47623	2 HORSESHOE LN	Р	Υ	1			
	47624	23 HYDE RD	Р	Υ	1			
	47625	2 INDIAN HILL RD	Р	Υ	1			
	47626	3 INDIAN HILL RD	Р	Υ	1			
	47627	6 INDIAN HILL RD	Р	Υ	1			
	47628	12 INDIAN HILL RD	Р	Υ	1			
	47629	12 INDIAN HILL RD	Р	Υ	1			
	4763	BUTLER BOOSTER STA	Α					
	47630	15 INDIAN HILL RD	Р	Υ	1			
	47631	18 INDIAN HILL RD	Р	Υ	1			
	47632	19 INDIAN HILL RD	Р	Υ	1			
	47633	22 INDIAN HILL RD	Р	Υ	1			
	47634	23 INDIAN HILL RD	Р	Υ	1			
	47635	26 INDIAN HILL RD	Р	Υ	1			
	47636	28 INDIAN HILL RD	Р	Υ	1			
	47637	31 INDIAN HILL RD	Р	Υ	1			
	47638	32 INDIAN HILL RD	Р	Υ	1			
	47639	33 INDIAN HILL RD	Р	Υ	1			
	4764	544 NEW BRITAIN AVE	Α					
	47640	37 INDIAN HILL RD	Р	Υ	1			
	47641	38 INDIAN HILL RD	Р	Υ	1			
	47642	40 INDIAN HILL RD	Р	Υ	1			
	47643	41 INDIAN HILL RD	Р	Υ	1			
	47644	43 INDIAN HILL RD	Р	Υ	1			
	47645	44 INDIAN HILL RD	Р	Υ	1			
	47646	1 LOWELL RD	Р	Υ	1			
	47647	2 LOWELL RD	Р	Υ	1			
	47648	3 LOWELL RD	Р	Υ	1			
	47649	5 LOWELL RD	P	Υ	1			
	47650	6 LOWELL RD	P	Y	1			
	47651	363 MAIN ST	Р	Y	1			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (v	vhere applicable)	Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	N AVE	Connections	5,87	7	349	47	46	

Wa	ater System Facili	ity and Sampling	Point In	ventor	v		
Water		ey and camping		Total	Lead and		
System Water System Facility	Sampling Point	Sampling Point		Coliform	Copper		Stage
Facility ID	ID	Description	Status	Rule		Asbestos	
	47652	367 MAIN ST	Р	Υ	1		
	47653	412 MAIN ST	Р	Υ	1		
	47654	15 MAPLEWOOD DR	Р	Υ	1		
	47655	8 MICHAEL DR	Р	Υ	1		
	47656	9 MICHAEL DR	Р	Υ	1		
	47657	11 MICHAEL DR	Р	Υ	1		
	47658	12 MICHAEL DR	Р	Υ	1		
	47659	14 MICHAEL DR	Р	Υ	1		
	47660	15 MICHAEL DR	Р	Υ	1		
	47661	17 MICHAEL DR	Р	Υ	1		
	47662	19 MICHAEL DR	Р	Υ	1		
	47663	20 MICHAEL DR	Р	Υ	1		
	47664	21 MICHAEL DR	Р	Υ	1		
	47665	22 MICHAEL DR	Р	Υ	1		
	47666	25 MICHAEL DR	Р	Υ	1		
	47667	26 MICHAEL DR	Р	Υ	1		
	47668	27 MICHAEL DR	Р	Υ	1		
	47669	28 MICHAEL DR	Р	Υ	1		
	47670	29 MICHAEL DR	Р	Υ	1		
	47671	30 MICHAEL DR	Р	Υ	1		
	47672	33 MICHAEL DR	Р	Υ	1		
	47673	34 MICHAEL DR	Р	Υ	1		
	47674	1 ASH CT	Р	Υ	2		
	47675	2 ASH CT	Р	Υ	2		
	47676	3 ASH CT	Р	Υ	2		
	47677	4 ASH CT	Р	Υ	2		
	47678	5 ASH CT	Р	Υ	2		
	47679	6 ASH CT	Р	Υ	2		
	47680	7 ASH CT	Р	Υ	2		
	47681	8 ASH CT	Р	Υ	2		
	47682	9 ASH CT	Р	Υ	2		
	47683	10 ASH CT	Р	Υ	2		
	47684	11 ASH CT	Р	Υ	2		
	47685	12 ASH CT	Р	Υ	2		
	47686	13 ASH CT	Р	Υ	2		
	47687	14 ASH CT	Р	Υ	2		
	47688	15 ASH CT	Р	Υ	2		
	47689	16 ASH CT	Р	Υ	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (where applicable)	Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAI	N AVE	Connections	5,87	7	349	47	46	

Towns Served:								
Wa	ter System Facili	ity and Samplin	g Point In	ventor	У			
Water	•			Total	Lead and			
System Water System Facility		Sampling Point		Coliform	Copper			age
Facility ID	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2 D	BPR
	47690	17 ASH CT	Р	Υ	2			
	47691	18 ASH CT	Р	Υ	2			
	47692	19 ASH CT	Р	Υ	2			
	47693	20 ASH CT	Р	Υ	2			
	47694	21 ASH CT	Р	Υ	2			
	47695	22 ASH CT	Р	Υ	2			
	47696	1 CARDINAL DR	Р	Υ	2			
	47697	2 CARDINAL DR	Р	Υ	2			
	47698	3 CARDINAL DR	Р	Υ	2			
	47699	4 CARDINAL DR	Р	Υ	2			
	47700	5 CARDINAL DR	Р	Υ	2			
	47701	6 CARDINAL DR	Р	Υ	2			
	47702	7 CARDINAL DR	Р	Υ	2			
	47703	8 CARDINAL DR	Р	Υ	2			
	47704	9 CARDINAL DR	Р	Υ	2			
	47705	10 CARDINAL DR	Р	Υ	2			
	47706	11 CARDINAL DR	Р	Υ	2			
	47707	12 CARDINAL DR	Р	Υ	2			
	47708	13 CARDINAL DR	Р	Υ	2			
	47709	14 CARDINAL DR	Р	Υ	2			
	47710	15 CARDINAL DR	Р	Υ	2			
	47711	16 CARDINAL DR	Р	Υ	2			
	47712	1 CYPRESS TRL	Р	Υ	2			
	47713	2 CYPRESS TRL	Р	Υ	2			
	47714	3 CYPRESS TRL	Р	Υ	2			
	47715	4 CYPRESS TRL	Р	Υ	2			
	47716	5 CYPRESS TRL	Р	Υ	2			
	47717	6 CYPRESS TRL	Р	Υ	2			
	47718	7 CYPRESS TRL	Р	Υ	2			
	47719	8 CYPRESS TRL	Р	Υ	2			
	47720	9 CYPRESS TRL	Р	Υ	2			
	47721	10 CYPRESS TRL	Р	Υ	2			
	47722	11 CYPRESS TRL	Р	Υ	2			
	47723	12 CYPRESS TRL	Р	Υ	2			
	47724	13 CYPRESS TRL	Р	Υ	2			
	47725	14 CYPRESS TRL	Р	Υ	2			
	47726	15 CYPRESS TRL	Р	Υ	2			
	47727	16 CYPRESS TRL	Р	Υ	2			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (v	vhere applicable)	Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46	

Wa	ter System Facili	ity and Sampling	Point In	ventor	v			
Water	ici oyotem i dem	ity and camping		Total	Lead and			
System Water System Facility	Sampling Point	Sampling Point		Coliform	Copper			Stage
Facility ID	ID	Description	Status	Rule		Asbestos	WQP	
	47728	1 EVERGREEN TRAIL	Р	Υ	2			
	47729	18 EVERGREEN TRAIL	Р	Υ	2			
	47730	2 EVERGREEN TRAIL	Р	Υ	2			
	47731	3 EVERGREEN TRAIL	Р	Υ	2			
	47732	4 EVERGREEN TRAIL	Р	Υ	2			
	47733	5 EVERGREEN TRAIL	Р	Υ	2			
	47734	6 EVERGREEN TRAIL	Р	Υ	2			
	47735	7 EVERGREEN TRAIL	Р	Υ	2			
	47736	8 EVERGREEN TRAIL	Р	Υ	2			
	47737	9 EVERGREEN TRAIL	Р	Υ	2			
	47738	10 EVERGREEN TRAIL	Р	Υ	2			
	47739	11 EVERGREEN TRAIL	Р	Υ	2			
	47740	12 EVERGREEN TRAIL	Р	Υ	2			
	47741	13 EVERGREEN TRAIL	Р	Υ	2			
	47742	14 EVERGREEN TRAIL	Р	Υ	2			
	47743	15 EVERGREEN TRAIL	Р	Υ	2			
	47744	16 EVERGREEN TRAIL	Р	Υ	2			
	47745	17 EVERGREEN TRAIL	Р	Υ	2			
	47746	19 EVERGREEN TRAIL	Р	Υ	2			
	47747	20 EVERGREEN TRAIL	Р	Υ	2			
	47748	1 FIELD ROCK RD	Р	Υ	2			
	47749	2 FIELD ROCK RD	Р	Y	2			
	47750	3 FIELD ROCK RD	Р	Y	2			
	47751	4 FIELD ROCK RD	Р	Y	2			
	47752	5 FIELD ROCK RD	Р	Y	2			
	47753	6 FIELD ROCK RD	Р	Y	2			
	47754	7 FIELD ROCK RD	Р	Y	2			
	47755	8 FIELD ROCK RD	P	Y	2			
	47756	9 FIELD ROCK RD	Р	Υ	2			
	47757	10 FIELD ROCK RD	P	Y	2			
	47758	11 FIELD ROCK RD	P	Y	2			
	47759	12 FIELD ROCK RD	P	Y	2			
	47739 47760	13 FIELD ROCK RD	P	Y	2			
	47761 47762	14 FIELD ROCK RD	Р	Y	2			
	47762	15 FIELD ROCK RD	P	Y	2			
	47763	16 FIELD ROCK RD	Р	Y	2			
	47764	17 FIELD ROCK RD	Р	Y	2			
	47765	18 FIELD ROCK RD	Р	Υ	2			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (v	vhere applicable)	Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46	

Wat	er System Facili	ity and Sampling	Point In	ventor	ν			
Water	•	, ,		Total	Lead and			
System Water System Facility	Sampling Point	Sampling Point		Coliform	Copper			Stage
Facility ID	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2	2 DBPI
	47766	19 FIELD ROCK RD	Р	Υ	2			
	47767	20 FIELD ROCK RD	Р	Υ	2			
	47768	21 FIELD ROCK RD	Р	Υ	2			
	47769	22 FIELD ROCK RD	Р	Υ	2			
	47770	23 FIELD ROCK RD	Р	Υ	2			
	47771	24 FIELD ROCK RD	Р	Υ	2			
	47772	1 GARDEN PATH	Р	Υ	2			
	47773	2 GARDEN PATH	Р	Υ	2			
	47774	3 GARDEN PATH	Р	Υ	2			
	47775	4 GARDEN PATH	Р	Υ	2			
	47776	5 GARDEN PATH	Р	Υ	2			
	47777	6 GARDEN PATH	Р	Υ	2			
	47778	7 GARDEN PATH	Р	Υ	2			
	47779	8 GARDEN PATH	Р	Υ	2			
	47780	9 GARDEN PATH	Р	Υ	2			
	47781	10 GARDEN PATH	Р	Υ	2			
	47782	11 GARDEN PATH	Р	Υ	2			
	47783	12 GARDEN PATH	Р	Υ	2			
	47784	13 GARDEN PATH	Р	Υ	2			
	47785	14 GARDEN PATH	Р	Υ	2			
	47786	15 GARDEN PATH	Р	Υ	2			
	47787	16 GARDEN PATH	Р	Υ	2			
	47788	17 GARDEN PATH	Р	Υ	2			
	47789	18 GARDEN PATH	Р	Υ	2			
	47790	19 GARDEN PATH	Р	Υ	2			
	47791	20 GARDEN PATH	Р	Υ	2			
	47792	21 GARDEN PATH	Р	Υ	2			
	47793	22 GARDEN PATH	Р	Υ	2			
	47794	23 GARDEN PATH	Р	Υ	2			
	47795	24 GARDEN PATH	Р	Υ	2			
	47796	25 GARDEN PATH	Р	Υ	2			
	47797	26 GARDEN PATH	Р	Υ	2			
	47798	27 GARDEN PATH	Р	Υ	2			
	47799	28 GARDEN PATH	Р	Y	2			
	47800	29 GARDEN PATH	Р	Υ	2			
	47801	30 GARDEN PATH	Р	Υ	2			
	47802	43 HAROLD RD	P	Y	2			
	47803	19-21 HAROLD RD	P	Y	2			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0520011 CTWC - UNIONVILLE SYSTEM					С	14,693	Р	SWP
Local Address (where applicable)		Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN AVE		Connections	5,87	7	349	47	46	

W	ater System Facili	ity and Sampling	Point In	ventor	٧			
Water System Water System Facility Facility ID	-	Sampling Point Description		Total Coliform Rule	Lead and Copper	Asbestos		Stage
denity ib	47804	33 HAROLD RD A/B	Status P	Y	2	ASDESTOS	VVQI 2	L DDI I
	47804 47805	1 LILAC LN	P P	Υ	2			
	47806	2 LILAC LN	P	Υ	2			
	47807	3 LILAC LN	r P	Y	2			
	47807	4 LILAC LN	r P	Y	2			
	47809	5 LILAC LN	r P	Y	2			
	47810	6 LILAC LN	P	Y	2			
	47810	7 LILAC LN	P	Y	2			
	47812	8 LILAC LN	' P	Y	2			
	47813	9 LILAC LN	Р	Y	2			
	47814	10 LILAC LN	P	Y	2			
	47815	11 LILAC LN	Р	Y	2			
	47816	12 LILAC LN	P	Y	2			
	47817	13 LILAC LN	Р	Υ	2			
	47818	14 LILAC LN	Р	Υ	2			
	47819	15 LILAC LN	Р	Υ	2			
	47820	16 LILAC LN	Р	Υ	2			
	47821	1 LOCUST LN	Р	Υ	2			
	47822	2 LOCUST LN	Р	Υ	2			
	47823	3 LOCUST LN	Р	Υ	2			
	47824	4 LOCUST LN	Р	Υ	2			
	47825	5 LOCUST LN	Р	Υ	2			
	47826	6 LOCUST LN	Р	Υ	2			
	47827	7 LOCUST LN	Р	Υ	2			
	47828	8 LOCUST LN	Р	Υ	2			
	47829	9 LOCUST LN	Р	Υ	2			
	47830	10 LOCUST LN	Р	Υ	2			
	47831	11 LOCUST LN	Р	Υ	2			
	47832	12 LOCUST LN	Р	Υ	2			
	47833	13 LOCUST LN	Р	Υ	2			
	47834	14 LOCUST LN	Р	Υ	2			
	47835	15 LOCUST LN	Р	Υ	2			
	47836	16 LOCUST LN	Р	Υ	2			
	47837	17 LOCUST LN	Р	Υ	2			
	47838	18 LOCUST LN	Р	Υ	2			
	47839	19 LOCUST LN	Р	Υ	2			
	47840	20 LOCUST LN	Р	Υ	2			
	47841	21 LOCUST LN	Р	Υ	2			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Clas	sification	Population	Owner Type	Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (where applicable)		Service	Residen	tial	Commercia	al Industri	al Combine	ed Agricultural
25 NEW BRITAIN	AVE	Connections	5,877	7	349	47	46	

	Water S	system Facili	ity and Sampling P	oint in	ventor	У		
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage 2 DBP
		47842	22 LOCUST LN	Р	Υ	2		
		47843	23 LOCUST LN	Р	Υ	2		
		47844	24 LOCUST LN	Р	Υ	2		
		47845	25 LOCUST LN	Р	Υ	2		
		47846	26 LOCUST LN	Р	Υ	2		
		47847	27 LOCUST LN	Р	Υ	2		
		47848	28 LOCUST LN	Р	Υ	2		
		47849	29 LOCUST LN	Р	Υ	2		
		47850	30 LOCUST LN	Р	Υ	2		
		47851	31 LOCUST LN	Р	Υ	2		
		47852	32 LOCUST LN	Р	Υ	2		
		47853	33 LOCUST LN	Р	Υ	2		
		47854	34 LOCUST LN	Р	Υ	2		
		47855	35 LOCUST LN	Р	Υ	2		
		47856	36 LOCUST LN	Р	Υ	2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	Α				
		UPSTREAM	WITHIN 5 SERVICE CON	Α				
00703	ENTRY POINT - WELLCTSS	3	EP - WELL CTS	Α				
00705	ENTRY POINT - WELLP	3	EP - WELL P	Α				
00707	ENTRY POINT - WELLS 1, 2, 3, 4 & 5	3	EP - WELLS 1, 2, 3,	Α				
00708	ENTRY POINT - FIP WELL #3	3	EP - FIP WELL #3	Α				
00709	ENTRY POINT - FIP WELL #4	3	EP - FIP WELL #4	Α				
051081	BUTLER ROAD BOOSTER SYSTEM							
1028	PONDWOOD WELL	2	PONDWOOD WELL	Α				
10829	FIP WELL #3	2	FIP WELL #3	Α				
10830	FIP WELL #4	2	FIP WELL #4	Α				
1295	C HOUSE WELL 5	2	C HOUSE WELL 5	Α				
1296	C HOUSE WELL 4	2	C HOUSE WELL 4	Α				
1297	C HOUSE WELL 3	2	C HOUSE WELL 3	Α				
1298	C HOUSE WELL 2	2	C HOUSE WELL 2	Α				
1299	C HOUSE WELL 1	2	C HOUSE WELL 1	Α				
1452	CT SAND & STONE WELL #1	2	CT. SAND AND STONE W					
47028	ANVIL DRIVE TANK							
47030	FARMINGTON TANK							
47032	SOUTHWEST TANK							
48928	INTERCONNECTION - MDC (RT-4)							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

	Connecticut Department o Water Quality Monit				C			
PWS ID PWS Name Classification Population Owner Type Pri								Primary Source
CT0520011	CTWC - UNIONVILLE SYSTEM				С	14,693	Р	SWP
Local Address (ocal Address (where applicable) Service Resi					al Industri	al Combine	ed Agricultural
25 NEW BRITA	N AVE	Connections	5,87	7	349	47	46	

T_{c}	าพ	ns	Se	rve	:b
	, , ,	113	90		и.

	Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP	Stage 2 DBPR	
85	CHARLES HOUSE WELL 4	5	EP - WELL 4	А						
87	CT SAND & STONE WELL #1 TP									
89	PONDWOOD WELL									
979	FIP WELL #3 TREATMENT PLANT									
980	FIP WELL #4 TREATMENT PLANT					·				

979	FIP WELL#3 II	REATIVIENT PLANT		
980	FIP WELL #4 TI	REATMENT PLANT		
		Certified Ope	rator Information	
Water S	ystem Facility:	DISTRIBUTION SYSTEM (WSF ID: 006	(00)	
Facility C	lassification: CL	ASS 2 DISTRIBUTION SYSTEM		Certification
Operator	r Name	Operator Type	Certification(s)	Expiration
ROBOTHA	AM, JR., PAUL C.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2020
			WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019
DUNNE, I	III, EDWARD P.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2019
			DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
RUZBASA	N, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021
			DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
RUOT, DA	AVID A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2020
Water S	ystem Facility:	CHARLES HOUSE WELL 4 (WSF ID: 85)	
Facility C	lassification: CL	ASS 1 TREATMENT PLANT		Certification
Operator	r Name	Operator Type	Certification(s)	Expiration
WINSLOV	N, KEITH	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2020
RUZBASA	N, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021
			DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
Water S	ystem Facility:	CT SAND & STONE WELL #1 TP (WSF	ID: 87)	
Facility C	lassification: CL	ASS 2 TREATMENT PLANT		Certification
Operator	r Name	Operator Type	Certification(s)	Expiration
DUNNE, I	III, EDWARD P.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2020
			WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2019
RUZBASA	N, STEPHEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
			WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2023
Water S	ystem Facility:	PONDWOOD WELL (WSF ID: 89)		
Facility C	lassification: CL	ASS 1 TREATMENT PLANT		Certification
Operator	r Name	Operator Type	Certification(s)	Expiration
RUZBASA	N, STEPHEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2022
			DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

	Water Quality Monitoring and Compliance Schedule								
PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source	
CT0520011	CT0520011 CTWC - UNIONVILLE SYSTEM				C 14,693		Р	SWP	
Local Address (w	Local Address (where applicable)		Residential		Commercia	al Industri	al Combine	ed Agricultural	
25 NEW BRITAIN	I AVE	Connections	5,87	7	349	47	46		

Connecticut Department of Public Health Drinking Water Section

Towns Served:										
			Certifi	ed Operat	or Information	1				
Water System Fac	cility: FIP W	ELL #3 TRE	ATMENT P	LANT (WSF II	D: 979)					
Facility Classification	on: CLASS 1 TF	REATMENT P	LANT						Certification	
Operator Name			Operator	Туре	Certification(s)			Expiration		
DUNNE, III, EDWAR	D P.		ASSIGNED (OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II				6/30/2019	
					DISTRIBUTION SYS	TEM OPE	RATOR - CLASS	Ш	6/30/2020	
RUZBASAN, STEPHE	EN		ASSIGNED (OPERATOR	WATER TREATMEN	IT PLANT	OPERATOR - C	LASS II	12/31/2021	
					DISTRIBUTION SYS	ТЕМ ОРЕ	RATOR - CLASS	II	6/30/2019	
Water System Fac	cility: FIP W	ELL #4 TRE	ATMENT P	LANT (WSF II	D: 980)					
Facility Classification	on: CLASS 1 TF	REATMENT P	LANT						Certification	
Operator Name Operator			Operator	Туре	Certification(s)				Expiration	
DUNNE, III, EDWARD P. ASSIGNED			ASSIGNED (OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III			LASS III	6/30/2019	
				DISTRIBUTION SYSTEM OPERATOR - CLASS III					6/30/2020	
RUZBASAN, STEPHE	EN		ASSIGNED (OPERATOR	DISTRIBUTION SYS	ТЕМ ОРЕ	RATOR - CLASS	II	6/30/2019	
					WATER TREATMEN	IT PLANT	OPERATOR - C	LASS II	12/31/2021	
			(Contact Inf	ormation					
Name				Organization	ı			Job Title		
Mr. Craig J. Patla				Connecticut	Water Company		Vp, Service Delivery			
Mailing Address Lin	e One		Mailing Add	dress Line Two			City	State	Zip Code	
93 West Main Stree	et					Clinton		СТ	06413	
Business Phone	Extension	Fax	N	Nobile Phone	Emergency Phone	Email A	ddress			
860-664-6140					800-391-1924	cpatla@	ctwater.com			
Contact Role(s): Le	egal Contact									
Name				Organization	l			Job Title		
Mr. David Connors				Connecticut	Connecticut Water Company			Director, Service De		
Mailing Address Line One Mailing Add				dress Line Two			City	State	Zip Code	
			93 West M	ain St		Clinton CT			06413	
Business Phone	Extension	Fax	N	Mobile Phone	Emergency Phone	Email A	ddress			
860-664-6141					860-227-4902	dconnoi	rs@ctwater.cor	n		

Please note the following:

Contact Role(s): Administrative Contact

- 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
- 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

http://www.ct.gov/dph/publicdrinkingwater

End of schedule

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0529051	CTWC - CHIMNEY HILL				С	227	Р	SWP
Local Address (where applicable)		Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
MOUNTAIN ROAD		Connections	46		1			

Towns Served: FARMINGTON			<u> </u>
Monitorin	g Requirements		
Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00	0600)		
Chlorine Residual (0999)		1 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
Asbestos (1094)		1 routine	(RT) per nine years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete
	3/1/19 - 3/31/19		
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		
	10/1/19 - 10/31/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 r	outine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
301 COLT HIGHWAY (4770)	1/1/18 - 12/31/18	9/1-9/30	Complete
	1/1/19 - 12/31/19	9/1-9/30	
	1/1/20 - 12/31/20	9/1-9/30	
Lead And Copper (PBCU)		5 r	outine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/19	6/1-9/30	
	1/1/20 - 12/31/20	6/1-9/30	
Physical Parameters (PPS)		1 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/18 - 11/30/18		Complete
	12/1/18 - 12/31/18		Complete
	1/1/19 - 1/31/19		Complete
	2/1/19 - 2/28/19		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0529051	CTWC - CHIMNEY HILL				С	227	Р	SWP
Local Address (where applicable)		Service	Resider	ntial	Commercial Industri		al Combine	ed Agricultural
MOUNTAIN ROAD		Connections	46		1			

Towns Served: FARMINGTON

Monitoring Red	quirements		
Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Physical Parameters (PPS)		1 rout	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	3/1/19 - 3/31/19		Complete
	4/1/19 - 4/30/19		
	5/1/19 - 5/31/19		
	6/1/19 - 6/30/19		
	7/1/19 - 7/31/19		
	8/1/19 - 8/31/19		
	9/1/19 - 9/30/19		_
	10/1/19 - 10/31/19		

Other C	ompliance Schedules		
Compliance Schedule Activity	Due Date	Achieved Date	
SUBMIT CCR TO THE DEPARTMENT	6/30/2019		
SUBMIT CCR CERTIFICATION FORM	8/9/2019		
CROSS CONNECTION SURVEY REPORT	3/1/2020		

CROSS CO	NNECTION SURVEY REPORT		3/:	1/2020				
	Wate	er System Facili	ity and Sampling P	oint Ir	nventor	У		
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBP
00600	DISTRIBUTION SYSTEM	4	CHIMNEY HILL DISTRIB	А	Υ			
		4770	301 COLT HIGHWAY	Α	Υ	N		Υ
		4771	4771 10 CHIMNEY HILL	Α	Υ	N		
		47710	47710 12 CHIMNEY HIL	Α	Υ	N		
		47711	47711 2 CHIMNEY HILL	Α	Υ	N		
		47712	47712 14 CHIMNEY HIL	Α	Υ	N		
		47713	47713 30 CHIMNEY HIL	Α	Υ	N		
		47715	47715 27 CHIMNEY HIL	Α	Υ	N		
		47716	1 CHIMNEY HILL	Α	Υ	N		
		47717	19 CHIMNEY HILL	Α	Υ	N		
		47718	21 CHIMNEY HILL	Α	Υ	N		
		47719	23 CHIMNEY HILL	Α	Υ	N		
		4772	4772 8 CHIMNEY HILL	Α	Υ	N		
		47720	24 CHIMNEY HILL	Α	Υ	N		
		47721	25 CHIMNEY HILL	Α	Υ	N		
		47722	26 CHIMNEY HILL	Α	Υ	N		
		47723	28N CHIMNEY HILL	Α	Υ	N		
		47724	3 HEARTHSTONE LN	Α	Υ	N		
		47725	4 HEARTHSTONE	Α	Υ	N		
		47726	5 HEARTHSTONE LN	Α	Υ	N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

PWS ID	PWS Name			Clas	ssification	Population	Owner Type	Primary Source
CT0529051	CTWC - CHIMNEY HILL				С	227	Р	SWP
Local Address (where applicable)		Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
MOUNTAIN ROAD		Connections	46		1			

Towns Served: FARMINGTON

	Wat	er System Facili	ty and Sampling P	oint Ir	nvento	у		
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		47727	6 HEARTHSTONE LN	Α	Υ	N		
		47728	7 HEARTHSTONE LN	Α	Υ	N		
		47729	8 HEARTHSTONE LN	Α	Υ	N		
		4773	4773 5 CHIMNEY HILL	Α	Υ	N		
		47730	9 HEARTHSTONE LN	Α	Υ	N		
		47731	17 HEARTHSTONE LN	Α	Υ	N		
		47732	18 HEARTHSTONE LN	Α	Υ	N		
		47733	2 HEARTHSTONE LN	Α	Υ	N		
		4774	4774 7 CHIMNEY HILL	Α	Υ	N		
		4775	4775 3 CHIMNEY HILL	Α	Υ	N		
		4776	4776 16 CHIMNEY HILL	Α	Υ	N		
		4777	4777 20 CHIMNEY HILL	Α	Υ	N		
		4778	4778 18 CHIMNEY HILL	Α	Υ	N		
		4779	4779 22 CHIMNEY HILL	Α	Υ	N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	Α				
		UPSTREAM	WITHIN 5 SERVICE CON	Α				
57797	INTERCONNECTION - MDC							

57787 INTERCONNECTION - MDC

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification, CNANT NAT	ED CVCTEM		
Facility Classification: SMALL WAT	ER SYSTEIVI		Certification
Operator Name	Operator Type	Certification(s)	Expiration
ROBOTHAM, JR., PAUL C.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2020
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2019
RUZBASAN, STEPHEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2019
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2021
RUOT, DAVID A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2020

RUOT, DAVID A.			ASSIGNED O	PERATOR	DISTRIBUTION SYS	I EIVI OPEI	RATOR - CLA	12/31/2020		
			Co	ontact Inf	ormation					
Name				Organization	1					
Mr. Craig J. Patla Co				Connecticut	necticut Water Company Vp, Service Del				elivery	
Mailing Address Line One Mailing Add				ress Line Two			City	State	Zip Code	
93 West Main Stree	et					Clinton		СТ	06413	
Business Phone	Extension	Fax	Mo	obile Phone	Emergency Phone	Email Address				
860-664-6140					800-391-1924	cpatla@ctwater.com				
Contact Role(s): Le	egal Contact									

Connecticut Department of Public Health Drinking Water Section											
	Wate	er Qua	lity Monit	oring ar	nd Con	nplia	nce S	chedul	e		
PWS ID P	PWS Name					Classif	ication Population O		Owner Type	Primary Source	
CT0529051 C	CTWC - CHIMNEY HILL					(227	Р	SWP	
Local Address (where applicable)				Service	Resider	ntial Co	mmercia	l Industri	al Combine	ed Agricultural	
MOUNTAIN ROAD				Connection	46		1				
Towns Served: FA	RMINGTON				,						
Name C				Organization			Job Title				
Mr. David Connors				Connecticut Water Company				Director, Service De			
Mailing Address Line One Mailing Addr				ess Line Two			City		State	Zip Code	
93 West Ma				ı St			Clinton		СТ	06413	
Business Phone	Extension	Fax	Mobi	le Phone	Emergency	mergency Phone		Email Address			
860-664-6141					860-227	-4902	dconnors@ctwater.com				
Contact Role(s):	Administrative Co	ontact									

Please note the following:

- 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
- 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

http://www.ct.gov/dph/publicdrinkingwater

End of schedule